




5. THE REFERENCE BUILDING OF IA-ECB ANNEX 59







Zone sensible heat balance:

$$\Delta U_{in,01} = \int_{\tau_1}^{\tau_2} dU/d\tau_{in,01} d\tau$$

$$\Delta U_{in,kWh,01} = \frac{\Delta U_{in,01}}{J/kWh}$$

$$\Delta U_{in,01} = C_{in,01} \cdot (t_{a,in,01} - t_{a,in,01,1})$$

$$C_{in,01} = ICF \cdot V_{in,01} \cdot c_{p,ref} / v_{ref}$$

Heat gains from adjacent rooms through internal walls, ceiling and floor


$$\dot{Q}_{s,in,intwalls,01} = \dot{Q}_{02,01} + \dot{Q}_{04,01} + \dot{Q}_{05,01} + \dot{Q}_{06,01} + \dot{Q}_{floor,01}$$

$$\dot{Q}_{02,01} = A_{1,2} \cdot U_{partition} \cdot (t_{a,in,02} - t_{a,in,01})$$


$$\dot{Q}_{floor,01} = A_1 \cdot U_{floor} \cdot \frac{t_{floor,01} - t_{a,in,01}}{f_{\theta,floor}}$$

$$\dot{Q}_{08,floor,01} = A_1 \cdot U_{floor} \cdot \frac{t_{a,in,08} - t_{floor,01}}{1 - f_{\theta,floor}}$$


$$Q_{storage,floor,01} = \int_{\tau_1}^{\tau_2} \dot{Q}_{storage,floor,01} d\tau$$




Occupancy schedule




Lighting schedule




Appliances schedule




Floating temperature with external temperature as only one thermal force




with also solar radiation



with also internal gains



With also ventilation and infiltration



Zone water gain:

$$\dot{M}_{w,zone,01} = (1 - \epsilon_{occdispl}) \cdot \dot{M}_{w,occ,01}$$


$$M_{w,zone,01} = \int_{\tau_1}^{\tau_2} \dot{M}_{w,zone,01} \, d\tau$$

Zone CO2 balance

$$\Delta M_{CO2,in,01} = \int_{\tau_1}^{\tau_2} dM_{CO2in}/d\tau_{01} d\tau$$

$$\Delta M_{CO2,in,01} = C_{CO2,in,01} \cdot (X_{CO2,in,01} - X_{CO2,in,01,1})$$

$$C_{CO2,in,01} = MM_{CO2} \cdot \frac{V_{in,01}}{v_a \cdot MM_{dryair}}$$



¹ RETURN AIR DUCT and RETURN FAN


$$\Delta p_{returnfan} = \Delta p_{returnduct} + \Delta p_{return,econo} + \Delta p_{return,recovery}$$

$$\epsilon_{s,returnfan} = \epsilon_{s,returnfan,n}$$


(might be also identified from fan characteristics)

$$\dot{W}_{returnfan} = f_{returnfan} \cdot \dot{V}_{a,returnfan} \cdot \frac{\Delta p_{returnfan}}{\epsilon_{s,returnfan}}$$


Ventilation schedule





Heating set points





Cooling set points
























EES Professional: D:\JL160901\Rendez-vous ATIC JL160901\Reference case Frankfurt JL160310-03 corrected.EES - [Diagram Window]

File Edit Search Options Calculate Tables Plots Windows Help Examples



Calculate

$$\tau_{\text{winter},1} = 0 \text{ [h]}$$

$$\tau_{\text{winter},2} = 8760 \text{ [h]}$$

$$\Delta\tau_{\text{winter}} = 0.5 \text{ [h]}$$

$$t_0 = 20 \text{ [C]}$$

$$Q_{\text{preheatingcoil,kWh}} = 81074 \text{ [kWh]}$$

$$Q_{\text{postheatingcoil,kWh}} = 87315 \text{ [kWh]}$$

$$Q_{\text{TUheatingcoils,kWh}} = 18359 \text{ [kWh]}$$

$$Q_{\text{boiler,kWh}} = 178165 \text{ [kWh]}$$

$$Q_{\text{gas,consumed,kWh}} = 212438 \text{ [kWh]}$$

$$\eta_{\text{boiler,HHV,average}} = 0.8387 \text{ [-]}$$

$$W_{\text{mainfan,kWh}} = 63462 \text{ [kWh]}$$

$$W_{\text{returnfan,kWh}} = 21968 \text{ [kWh]}$$

$$W_{\text{TUfans,kWh}} = 25896 \text{ [kWh]}$$

$$W_{\text{heatingpumps,kWh}} = 8584 \text{ [kWh]}$$

$$W_{\text{coolingpumps,kWh}} = 77044 \text{ [kWh]}$$

$$Q_{\text{sun,kWh}} = 340658 \text{ [kWh]}$$

$$Q_{\text{s,occ,kWh}} = 165361 \text{ [kWh]}$$

$$W_{\text{light,kWh}} = 634279 \text{ [kWh]}$$

$$W_{\text{appl,kWh}} = 599046 \text{ [kWh]}$$

$$W_{\text{total,kWh}} = 1.721\text{E}+06 \text{ [kWh]}$$

$$Q_{\text{cooling,AHU,kWh}} = 138171 \text{ [kWh]}$$

$$Q_{\text{TUcoolingcoils,kWh}} = 598031 \text{ [kWh]}$$

$$Q_{\text{evaporators,kWh}} = 813246 \text{ [kWh]}$$

$$W_{\text{chillers,kWh}} = 290911 \text{ [kWh]}$$

$$\text{COP}_{\text{average}} = 2.796 \text{ [-]}$$

$$\text{PPD}_{\text{average},01} = 6.165 \text{ [%]}$$

$$\text{PPD}_{\text{average},02} = 6.21 \text{ [%]}$$

$$\text{PPD}_{\text{average},03} = 6.406 \text{ [%]}$$

$$\text{PPD}_{\text{average},04} = 6.337 \text{ [%]}$$

$$\text{PPD}_{\text{average},05} = 9.527 \text{ [%]}$$

