

BUILDING DYNAMIC SIMULATION

Rendez-vous de l'ATIC


15th January 2020

Gabrielle Masy

Lecturer HEPL – Researcher UCLouvain






Static system




$$\dot{q} = U(t_{out} - t_{in})$$

$$\bar{q} = U(\bar{t}_{out} - t_{in})$$




$$\Delta q = U(\Delta t_{out} - t_{in})$$



Dynamic system



$$\Delta t_{eq} = \frac{\dot{q}}{U}$$






DYNAMIC SIMULATION - PRINCIPLES

- Differential equations

$$\begin{bmatrix} \frac{dT_1}{dt} \\ \frac{dT_2}{dt} \end{bmatrix} = \begin{bmatrix} -\frac{1}{RC} - \frac{hA}{C} & \frac{1}{RC} \\ \frac{1}{RC} & -\frac{1}{RC} - \frac{hA}{C} \end{bmatrix} \begin{bmatrix} T_1 \\ T_2 \end{bmatrix} + \begin{bmatrix} \frac{hA}{C} & 0 \\ 0 & \frac{hA}{C} \end{bmatrix} \begin{bmatrix} T_o \\ T_i \end{bmatrix}$$

- Convolution model based on response factors



DYNAMIC SIMULATION TOOLS




BEMS team, ULg

Web : <http://www.bems.ulg.ac.be>

Library energy system components

- **Solar** Thermal Processes
- **Ground** Coupled Heat Transfer
- **Heat Pump** Systems
- Coupled Multizone Thermal/**Airflow** Modeling
- **Power Plants** (Biomass,Cogeneration)
- Hydrogen **Fuel Cell** Systems
- **Wind and Photovoltaic** Systems
- **HVAC** systems
- Emerging Technology **Assessment**
- Energy System **Research**
- Data and Simulation **Calibration**
- **Optimization**



DYNAMIC SIMULATION - APPLICATIONS

System sizing

Energy
Consumptions

Validation

Identification

CASE STUDY




Glazing : $U_w = 1,8 \text{ W/m}^2\text{-K}$, SHGC = 0.49 frame factor 10 %

Bricks $U = 0,24 \text{ W/m}^2\text{-K}$

Sprandel walls $U = 0,24 \text{ W/m}^2\text{-K}$




Roof $U = 0,18 \text{ W/m}^2\text{-K}$

Bricks – Sprandel walls - Windows




Comfort requirements

- Fresh air per occupant: 40-50 m³/h
- Internal temperature: 20 à 26 °C
- Internal relative humidity: 40 à 60 %




Source: www.energieplus-lesite.be



HEAT GAINS



Uniforme: 10 W/m²




Général: 20 W/m²




HEAT GAINS vs HEAT LOADS

$$\dot{Q}_l = f_{ad} \cdot \dot{Q}_{l,m}$$


\dot{Q}_l Heat gains W
 f_{ad} Cooling Load Factor (hour by hour) -
 $\dot{Q}_{l,m}$ Heat loads W




CONVECTIVE vs RADIATIVE HEAT GAINS




Convective heat gains



Radiative heat gains



LIGHTING AND OCCUPANCY LOADS




Radiative fraction of Heat gains

Heat gains from to

Plant working from to

Maximum load factor: 0.97






Load_factors																	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
$f_{ad,0}$	$f_{ad,1}$	$f_{ad,2}$	$f_{ad,3}$	$f_{ad,4}$	$f_{ad,5}$	$f_{ad,6}$	$f_{ad,7}$	$f_{ad,8}$	$f_{ad,9}$	$f_{ad,10}$	$f_{ad,11}$	$f_{ad,12}$	$f_{ad,13}$	$f_{ad,14}$	$f_{ad,15}$	$f_{ad,16}$	$f_{ad,17}$
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.87	0.93	0.94	0.94	0.95	0.95	0.96	0.96	0.96	0.97

SOLAR HEAT LOADS - WINDOWS


$$\dot{Q}_s = f_{ad,gl} \cdot g \cdot A_{gl} \cdot \phi_{t_{max}}$$

- \dot{Q}_s Heat gains W
- $f_{ad,gl}$ Cooling Load Factor shading incl.
- $\phi_{t_{max}}$ Max total solar irradiation W/m^2



SOLAR HEAT LOADS - WINDOWS

Loads Values Evaluation



Convection heat exchange coefficient

$[\text{W/m}^2\text{-K}]$


Plant working from

to


Maximum solar intensity on window: $507 \text{ [W/m}^2\text{]}$

Maximum hourly average load factor: 0.73


Maximum intensity times load factor: $370.1 \text{ [W/m}^2\text{]}$



$A1 = 0 \text{ [deg]}$




$A2 = 0 \text{ [deg]}$




$DH = 0$



$A3 = 0 \text{ [deg]}$




SOLAR HEAT LOADS – OPAQUE WALLS



External equivalent temperature July, South





SOLAR HEAT LOADS – OPAQUE WALLS



$$\Delta t_{eq} = \frac{\dot{q}}{U}$$

$U=2.00 \text{ W/m}^2\text{K}$




HEAT GAINS

	Heat Gains	Load Factor	Heat Loads
Occupants Lighting Equipment	Radiative		$\dot{Q} = f_{ad} \cdot \dot{Q}_{rad,max}$
	Convective		$\dot{Q} = f_{ad} \cdot \dot{Q}_{conv,max}$
Windows	Radiative		<div style="border: 2px solid red; border-radius: 15px; padding: 5px; display: inline-block;">Internally accessible mass</div> $\dot{Q} = f_{ad,gl} \cdot g \cdot A_{gl} \cdot \Phi_{s,max}$
	Transmission		$\dot{Q}_{tr} = AU(t_{out} - t_{in})$
Opaque walls	Radiative + Transmission		<div style="border: 2px solid red; border-radius: 15px; padding: 5px; display: inline-block;">Total mass</div> $\dot{Q}_{tr} = AU\Delta t_{eq}$

COOLING SYSTEM SIZING

Hour (summer)		2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	0	1
Hour (solar time)		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Step 100% radiative CLF		0,18	0,14	0,11	0,09	0,07	0,07	0,28	0,43	0,54	0,63	0,7	0,75	0,8	0,83	0,86	0,88	0,9	0,91	0,73	0,57	0,45	0,36	0,28	0,23	0,18
Light & occ radiative loads (W)	144	26	20	16	13	10	10	40	62	78	91	101	108	115	120	124	127	130	131	105	82	65	52	40	33	26
Step 100 % convective CLF		0,09	0,07	0,06	0,04	0,04	0,25	0,65	0,72	0,78	0,82	0,85	0,88	0,9	0,92	0,93	0,94	0,95	0,96	0,36	0,28	0,22	0,17	0,14	0,11	0,09
Light & occ convective loads (W)	216	19	15	13	9	9	54	140	156	168	177	184	190	194	199	201	203	205	207	78	60	48	37	30	24	19
South Solar CLF - July		0,01	0	0	0	0	0	0,02	0,04	0,06	0,08	0,09	0,1	0,11	0,11	0,11	0,11	0,11	0,11	0,1	0,08	0,06	0,04	0,02	0,01	0,01
South Solar heat loads (W)	832	8	0	0	0	0	0	17	33	50	67	75	83	91	91	91	91	91	91	83	67	50	33	17	8	8
West Solar CLF - July		0,04	0,02	0,01	0,01	0	0	0,01	0,03	0,04	0,06	0,07	0,07	0,08	0,08	0,08	0,08	0,08	0,11	0,22	0,31	0,32	0,22	0,12	0,07	0,04
West Solar heat loads (W)	1094	44	22	11	11	0	0	11	33	44	66	77	77	88	88	88	88	88	120	241	339	350	241	131	77	44
South brick wall DTE- July (K)		6,4	5,9	5,2	4,4	3,5	2,6	1,6	0,5	-0,4	-1,3	-1,9	-2,3	-2,1	-1,5	-0,4	1	2,5	4,1	5,4	6,4	7	7,3	7,2	7	6,5
South brick wall (W)	1,34	9	8	7	6	5	3	2	1	-1	-2	-3	-3	-3	-2	-1	1	3	5	7	9	9	10	10	9	9
South spandrel wall DTE- July (K)		-4,7	-6,8	-9,3	-10,3	-10,9	-10,2	-9,1	-6,8	-1,7	6	13,2	18,4	21,8	22,4	20,8	17	12	6,4	4,5	2,7	0,6	-1,1	-2,6	-3,7	-4,7
South spandrel wall (W)	1,34	-6	-9	-12	-14	-15	-14	-12	-9	-2	8	18	25	29	30	28	23	16	9	6	4	1	-1	-3	-5	-6
West brick wall DTE- July (K)		9,6	9,1	8,4	7,5	6,4	5,2	4	2,7	1,6	0,5	-0,3	-1	-1,3	-1,4	-1,2	-0,8	0	1,2	2,7	4,5	6,3	7,9	9,1	9,7	9,6
West brick wall (W)	0,89	9	8	7	7	6	5	4	2	1	0	0	-1	-1	-1	-1	-1	0	1	2	4	6	7	8	9	9
West spandrel wall DTE- July (K)		-4,7	-6,8	-9,3	-10,3	-10,9	-10,2	-9,1	-6,8	-4	-1	2,1	4,4	6,4	12,7	20	25,2	28	27,6	23,8	16,1	3,1	-1	-2,6	-3,7	-4,7
West spandrel wall (W)	1,34	-6	-9	-12	-14	-15	-14	-12	-9	-5	-1	3	6	9	17	27	34	37	37	32	22	4	-1	-3	-5	-6
Roof DTE - July (K)		-4,3	-6	-8,4	-9,9	-10,6	-8,8	-3,1	5,7	16,3	27	36,6	44,1	48,9	50,6	49,2	44,9	38,3	29,9	20,6	11,4	4,1	0	-1,9	-3,3	-4,3
Roof (W)	1,51	-7	-9	-13	-15	-16	-13	-5	9	25	41	55	67	74	77	74	68	58	45	31	17	6	0	-3	-5	-7
External dry temperature (°C)		21	18,5	16	15,5	15	15,5	16	18,5	21	24	27	29	31	31,5	32	31,5	31	30	29	27,5	26	24,5	23	22	21
DT dry- July (K)		-5	-7,5	-10	-10,5	-11	-10,5	-10	-7,5	-5	-2	1	3	5	5,5	6	5,5	5	4	3	1,5	0	-1,5	-3	-4	-5
Windows transmission gains (W)	12,05	-60	-90	-121	-127	-133	-127	-121	-90	-60	-24	12	36	60	66	72	66	60	48	36	18	0	-18	-36	-48	-60
Infiltration sensible gains (W)	11,00	-55	-83	-110	-116	-121	-116	-110	-83	-55	-22	11	33	55	61	66	61	55	44	33	17	0	-17	-33	-44	-55
Total heat load (W)		-20	-127	-214	-239	-270	-210	-46	104	243	400	532	620	712	744	769	761	744	740	655	638	539	342	157	53	-20

HEATING SYSTEM SIZING



- Transmission losses:
 - 400 W
- Ventilation & Infiltration :
 - 180 W with recovery HX
 - 720 W no recovery HX
- Heating restart
 - 620 W
- Total
 - 1200 W with recovery HX
 - 1700 W no recovery HX

DYNAMIC SIMULATION - APPLICATIONS

System sizing



Energy
Consumptions

Validation

Identification

CASE STUDY

Glazing : $U_w = 1,8 \text{ W/m}^2\text{-K}$, $\text{SHGC} = 0.49$ frame factor 10 %



TYPICAL PERIMETER SECTION


IMPROVEMENT STEPS

- Reference:
 - Suspended ceiling and raised floor, no solar screens
- Envelope :
 - Accessible thermal mass
 - Solar shading
- System control improvement:
 - Daytime free cooling : bypass of the heat recovery exchanger
 - Night free cooling
 - Optimized free cooling control

Envelope :



- Extra insulation thickness for external walls (+ 5 cm)

REFERENCE





- Average weather data
- Temperature set points :
 - Summer 26°C / 30°C
 - Winter 21°C / 16°C
- Occupancy:
 - 8 h – 18 h
 - 7.5 m²/occ
 - 40 m³/h.occ fresh air
 - 6 W/m² lighting
 - 10 W/m² appliances
- Heat recovery exchanger



ENVELOPE IMPROVEMENTS




SYSTEM CONTROL IMPROVEMENT





OPTIMIZATION FREE COOLING SET POINT




Energy Cost vs free cooling temperature set point (EUR/m²)





EXTRA ENVELOPE INSULATION



THERMAL COMFORT – NO CHILLER



THERMAL COMFORT – NO CHILLER



CONCLUSION

- Dynamic simulation of building:
 - Sizing of Heating and cooling systems
 - Prediction of energy consumption
 - Prediction of thermal comfort
- Improvements options:
 - Shading systems
 - Optimization of control >>> ROI < 15 years
 - Envelope insulation >>> ROI > 15 years

DYNAMIC SIMULATION - APPLICATIONS

System sizing

Energy
Consumptions

Validation

Identification

VALIDATION OF SIMULATION TOOLS

IEA EBC Annex 71 Holzkirchen Twin Test Houses




VALIDATION OF SIMULATION TOOLS

Calculated vs measured solar irradiation on facades




IEA EBC Annex 71 Holzkirchen



BLIND EXPERIMENT


Temperature set point > Heating Power ?

Measured Heating power > temperature ?



VALIDATION OF SIMULATION TOOLS

IEA EBC Annex 71 Holzkichen Twin Test Houses



VALIDATION OF SIMULATION TOOLS



IEA EBC Annex 71
Holzkichen Twin Test Houses





Figure 21: External installation of the Twin Houses Vaillant "aroTHERM VWL 55/2 A" air source heat pump, left in summer, right in winter.


VALIDATION OF SIMULATION TOOLS

IEA EBC Annex 71 Holzkirchen Twin Test Houses







SRATIFICATION EFFECT

- Child1 zone electric radiators : 5 °C on average, 10°C maximum








Holzkirchen Twin Test Houses Experiment 2019/01/01 - 2019/01/10 : House n2, zone child 1





INTERNAL THERMAL BRIDGES

Saints Pierre et Paul, Neder-Hover-Heembeek, Cam(b)bridge Project supported by innoviris



DYNAMIC SIMULATION - APPLICATIONS

System sizing


Energy
Consumptions

Validation

Identification

PARAMETRIC IDENTIFICATION


IEA EBC Annex 71 Loughborough case



- Use of the monitored radiator temperatures to split the boiler heat output into the different building zones
- Multi-zone modelling using internal temperatures measured by zone


PARAMETRIC IDENTIFICATION

Use of monitored radiator temperatures to split boiler heat output into the zones



Morning Afternoon & Evening

Ordinary day Week-end



Radiators AU's – 4 days static analysis

$$\dot{Q}_{rad} = m_w \frac{d\theta_w}{dt} + AU (\theta_w - \theta_{in})^n$$

$$n = 1.3$$



$$m_w = 0.011 \dot{Q}_n \quad \dot{Q}_n = AU(\theta_{w,n} - \theta_{in,n})^n$$

$$\dot{Q}_{rad} = AU \left(0.011 \cdot (\theta_{w,n} - \theta_{in,n})^n \frac{d\theta_w}{dt} + (\theta_w - \theta_{in})^n \right)$$

$$\theta_{w,n} = 70^\circ$$



$$\theta_{in,n} = 20^\circ$$

Radiator	AU [W/K]	$Q_{rad,n}$ [W]
Living	15.39	2488
Hall	17.13	2770
Dining	16.13	2608
Bed2	17.6	2846
Bath	9.94	1608
Bed1	12.96	2095




Zones HLC's – 10 days static analysis

$$\dot{Q}_{rad} + \dot{Q}_{in} + \dot{Q}_{sol} = HLC (\theta_{in} - \theta_{out})$$





Zone	HLC [W/K]	HLC std [W/K]
House	308.04	56.38
Hall	137.88	47.17
Bed2	48.64	35.83
Living	43.11	15.21

Living zone – 10 days dynamic analysis



- T0 External
- T1 Living
- T3 Hall and Dining
- T5 Neighbor 18°C
- T6 Bed2
- T7 Hall
- facs Solar gains factor
- fach Heat input factor
- facm Ventilation coupling factor

U00	[W/K]	0.02
U01	[W/K]	296.01
U1	[W/K]	35.21
tau0	[h]	18155
tau1	[h]	0.17
tau2	[h]	46.81
facs	[-]	1.51
fach	[-]	1.50
facm	[-]	2



CONCLUSION

- Validation of dynamic simulation tools:
 - Assessment of solar heat gains
 - Modelling of air stratification effect
 - Presence of internal thermal bridges
- Parametric identification:
 - Towards Effective Performance Assessment
 - Building Envelope Heat Loss Coefficient
 - Efficiencies of HVAC systems
 - Assessment of uncertainties associated to measurements